

# Concepts for Cost Reduction in CSP Power Plants

Robert Pitz-Paal, Stefano Giuliano, Michael Wittmann  
DLR; Institute of Solar Research, Köln

## Abstract

In solar thermal power plants concentrating collectors are used to provide the high-temperature heat for the power plant. There are a number of different concepts available in which the heat transfer fluid is either directly used in the power plant cycle (e.g. water vapor), or alternatively a secondary cycle with a different fluid (e.g. thermal oil) is used to collect the solar energy. To date, especially parabolic trough systems that use synthetic thermal oil as heat transfer medium are the dominant technology in the market. However alternative approaches that use other concentrator geometries (like central receiver tower power plants) and /or alternative heat transfer fluids are increasingly showing up. The lecture introduces two different concepts that use molten salt as heat transfer as well as storage medium. Technological strengths and weaknesses as well as expectations with respect to efficiency and cost are discussed.

## 1. Introduction to CSP Technology

Concentrating Solar Thermal Power (CSP) systems use high temperature heat from concentrating solar collectors to generate power in a conventional power cycle instead of - or in addition to - burning fossil fuel. Only direct radiation can be concentrated in optical systems. In order to achieve significant concentration factors sun-tracking is required during the day, involving a certain amount of maintenance. Therefore, the concept is most suitable for centralized power production, where maintenance can be performed efficiently, and in




Fig. 1: Design options for CSP Technology with thermal storage [IEA]

areas with high direct solar radiation levels. The benefit of this technology option compared to the utilization of photovoltaic cells that convert solar radiation to electricity directly is that the high temperature heat can be easily stored by putting the heat transfer fluid in large



## Technology

Most of today's commercial CSP power plants ( $>3 \text{ GW}_e$ ) are based on the design of the ANDASOL parabolic trough power plant (see Fig. 2) that was put in operation in Spain in November 2008. The plant design integrates three different fluid cycles: a eutectic mixture of 73.5 % diphenyl oxide and 26.5 % biphenyl is used as heat transfer fluid in the collector field. It is operated between  $290^\circ$  and  $390^\circ\text{C}$  (that is also the upper temperature limit of that thermal oil) and provides the collected heat through heat exchangers either to the thermal storage cycle or to the power cycle. The latter uses water steam like in conventional power plants whereas a eutectic mixture of  $\text{KNO}_3$  and  $\text{NaNO}_3$  is used as storage medium that is operated almost in the same temperature range as the collector fluid. It is selected as it is about 4 times cheaper than the thermal oil. The salt is contained in two tanks, one on a lower temperature of about  $290^\circ\text{C}$  and after being heated up in the heat exchanger in a hot tank at almost  $390^\circ\text{C}$ . The salt mixture material is available extensively in nature (mining) and used also as fertilizer with a capacity of many 100 of thousands of tons per year. As it freezes at  $238^\circ\text{C}$  it needs to be kept above significantly that temperature during the lifetime of the power plant. The storage density of such a system is approximately  $78 \text{ kWh}_{\text{th}}/\text{m}^3$  or  $42 \text{ kWh}_{\text{th}}/\text{t}$ . To provide a  $100 \text{ MW}_e$  trough power plant with a 6 hour of storage capacity about 38,000 t of salt are required. The largest commercial installation that uses such a storage system was put in operation in October 2013. It is the  $280 \text{ MW}_e$  Solana plant in Arizona (US) equipped with a 6 hours storage equivalent to  $4,400 \text{ MWh}_{\text{th}}$  of storage capacity distributed in 6 pairs of tanks of hot and cold salt each about 38 m in diameter and 14 m high. The heat losses of such tanks are significantly below 3% of the energy throughput and even two weeks of interruption does not require active heating for freezing protection of the storage tanks. Heat exchangers, pumps valves and piping need to be equipped with electrical trace heating to avoid freezing problems during start-up.

Such a power plant concept can achieve annual gross solar-to-electric efficiency figures of up to 16%.


### 3. Concepts for Cost Reduction

The current concept has a number of limitations in terms of power plant efficiency and storage density that lead to the development of alternative designs. First, the synthetic oil heat transfer is rather expensive and limited in temperature to approximately  $400^\circ\text{C}$ . This limits on the one hand the potential life steam conditions in the power block and thus the efficiency of the power cycle to values below those of fossil fuel driven steam power plants. Second it limits the amount of heat that can be stored in the salt as it depends on the temperature difference between hot and cold tank. Steam has been investigated as alternative heat transfer fluid that is also used in the power cycle; however the integration into a storage system is difficult as the phase change characteristics of the steam during evaporation leads to a temperature profile that does not correspond to the sensible heating of the salt mixture. Using salt also as heat transfer fluid may overcome many of the limitations as the operation temperature of the salt can be extended to  $550^\circ\text{C}$  which is a more typical operation temperature of conventional steam cycle power plants. Such a replacement would also avoid the expensive thermal oil cycle. The challenge, however, is to avoid freezing of the salt in the extended collector field in any circumstance. This is addressed in two different concepts that are discussed in the following.

#### 3.1. Molten Salt Power Tower

In solar tower systems a field of individually tracked mirrors (heliostats) concentrates the solar radiation on a heat exchanger located on top of a central tower. In such a point-focus

arrangement higher concentration factors ( $\approx 1000$ ) can be archived compared to parabolic trough technology ( $\approx 100$ ) that generates a line-focus. The collection of the energy is not performed by an extended piping circuit of more than 100 km length (including the parabolic trough receiver tubes) like in a parabolic trough field but rather by transferring the “radiation energy” to a central location limiting the piping length to a couple of 100 m necessary to transport the heat transfer fluid from the top of the tower to the storage and steam generator system located on the ground (see Fig. 3). The arrangement has the benefit that gravity supports the draining of the complete salt fluid back to the storage tanks during times where operation is not foreseen (e.g. overnight) which reduces the auxiliary electric power requirements to trace heat the piping in order to avoid freezing, in the case that molten salt is used as heat transfer and storage fluid. However, such arrangement also shows some significant drawbacks: A liquid salt column of 100 m equals 19 bar pressure. As the tower in a commercial solar system is typically more than 150 m tall and the pressure in the storage tanks at the ground level should be kept close to atmospheric pressure to limit its construction cost, the salt circulation system cannot be designed as a closed circuit in which only friction losses need to be overcome by the pump. In an open cycle the energy required to lift the salt to the tower top needs also to be invested.



*Fig. 3: Schematic of a Solar Tower Systems using salt as heat transfer and storage fluid integrated into a steam cycle power plant [4]*

For the temperatures given in Fig. 3 each kilogramme of salt carries 416 kJ of thermal energy out of which approximately 166 kJ of electricity will be produced. To lift up the salt a 200 m tall tower with an annual average pump efficiency of 50% -60% [18] almost 2% of this electricity is required just to overcome the gravity. In particular challenging is the start-up of a drained receiver heat exchanger. Such a receiver consists of several irradiated panels that are connected in series. The fluid is first brought to the tower top to electrically preheated vessels (see Fig. 4 left). The header of each panel is also insulated and equipped with radiant heaters for preheating. The panel itself is heated up by concentrated radiation of the heliostat field starting with small number of heliostats and a low flow rate. Special experience is needed on the one hand side to avoid a freezing by too cold piping and on the other to limit material stresses by adjustment of the temperature gradients.

In Fig. 5 the overall effectiveness of such a system has been analyzed theoretically on an annual base. Approximately 57% of the solar energy on the heliostat field is collected as useful heat in the salt. Heat losses of the tanks as well as trace heating requirements are very small whereas pumping requirements of the salt, power block and condenser are the major auxiliary demand. Overall net efficiency of almost 17% is expected to be achievable by such a concept.




Fig. 4: Design of a Molten Salt Receiver System (left Receiver overview[16]; right details on trace heating[17])




Fig. 5: Exemplary Sankey Diagram for power tower system using molten salt heat transfer and storage fluid.





Fig. 6: Cost reduction potential for future power tower systems using molten salt (Data from [1] and own calculations)

The levelized cost of electricity for such a system of 100 MWe power is estimated to be around 12€cents/kWh. Further cost reduction is particularly envisaged by mass production of the heliostat field as well as of scaling of the power plant to 200 MW. Also the operation at slightly increased temperatures of 580°C together with a further advanced heliostat design may give a further 10% reduction reaching a level of about 9 €cent/kWh if corrosion challenges aspects can be handled without major cost increase (Fig. 6). The technology has been developed already during the end of last century in a number of research and pilot projects as listed in table 1. The implementation of the commercial projects as listed in table 2 started just recently and will prove in the next couple of years whether such expectations can be met.



	MSEE (1985)	Thémis (1983-1986)	Solar Two (1996-1999)
Site	Albuquerque (New Mexico)	Targassonne (Frankreich)	Daggett (California)
Design	Martin Marietta	CNIM	Rocketdyne
HTF	Solar Salt	Hitec	Solar Salt
Receiver type	Cavity	Cavity	External
Thermal power	5 MW <sub>th</sub>	9 MW <sub>th</sub>	42.2 MW <sub>th</sub>
Electrical power	0.75 MW <sub>el</sub>	2 MW <sub>el</sub>	10 MW <sub>el</sub>

Table 1: Research and demonstration projects using molten salt tower technology [2-4]



	Gemasolar	Crescent Dunes	Cerro Dominador	Supcon Solar
Status	In Operation	In Construction	In Construction	In Construction
Site	Sevilla, Spain	Tonopah, Nevada	Calama, Chile	Delingha, China
Design	SENER/CIEMAT	SolarReserve	Abengoa	Supcon Solar
HTF	Solar Salt	Solar Salt	Molten Salt	Molten Salt
Receiver type	External	External	External	External
Thermal power	120 MW <sub>th</sub>	560 MW <sub>th</sub>	not public	not public
Storage capacity	15 h	15 h	18 h	2.5 h
Electrical power	20 MW <sub>el</sub>	110 MW <sub>el</sub>	110 MW <sub>el</sub>	50 MW <sub>el</sub>

Table 2: Commercial projects using molten salt tower technology [14, 15]

### 3.2. Parabolic Trough with molten salt heat transfer fluids

The concept has been transferred also to the parabolic trough system (Fig. 7). In this case the molten salt needs to be circulated through the whole collector field (>100 km of piping) and a complete draining of the systems (e.g. overnight) does not seem to be an attractive option. In order to prevent the salt from freezing in the absorber tubes a continuing recirculation is foreseen using salt from the cold tank and redirecting it back to the cold tank. Any drop in temperature of the cold tank will be compensated by small amounts of solar-heated molten salt from the hot tank. Once the hot tank is empty the heat will be provided by the auxiliary heater. Typically the auxiliary heater is not used after a sunny day. As molten salt always circulates through the solar field, it requires energy for pumping. The additionally installed electric heating devices are only installed for emergency cases and will not be used in a regular operation of the plant.




Fig. 7: Schematic of a parabolic trough power plant integrated into a steam power cycle using molten salt directly as heat transfer fluid and storage fluid (recirculation piping for night operation not shown in this figure)

The freezing temperature of the salt significantly influences the amount energy required, so that different salt mixtures with lower freezing temperatures are also under consideration to be used in parabolic trough systems. Two potential ternary salt mixtures are listed in table 3. Their freezing temperature are around 150°C, however the upper temperature that can be exploited is also lower than the upper temperature of the reference binary salt NaK-NO<sub>3</sub>. The cost of the Li-based ternary salt mixture is significantly higher, so that one option could be to use it only as heat transfer fluid and keep to the reference salt in the storage, however adding costs for additional heat exchangers. Another important factor influencing the amount of energy for the recirculation is the amount of solar radiation available, as in times where the sun shines no additional effort for recirculation is required. In Fig. 8, the amount of hours (anti-freeze) that need support from the storage or fossil fuel heating are shown for two different sites (e.g. different solar radiation) and different heat transfer fluids. Under favorable conditions, new salt mixture limit the amount of fossil fuel energy required for anti-freezing drastically [10].

<i>Salt Mixtures</i>	<i>Decomposition Temperature</i>	<i>Freezing Temperature</i>
<i>NaK-NO<sub>3</sub></i>	<i>&gt;550°C</i>	<i>238°C @ 60/40 Mixture</i>
<i>NaKCa-NO<sub>3</sub></i>	<i>&lt;500°C</i>	<i>~150°C</i>
<i>NaKLi-NO<sub>3</sub></i>	<i>~530°C</i>	<i>~140°C</i>

Table 3: Properties of different molten salt mixtures [5,7,9]




Fig. 8: Number of Hours in different operation regimes in a parabolic trough power plant using molten salt or thermal oil as heat transfer fluid (A=NaK-NO<sub>3</sub>; B=NaKCa-NO<sub>3</sub>; C=NaKLi-NO<sub>3</sub>; VP1 = Thermal Oil)

In Fig. 9 the overall effectiveness of such a system has been analyzed theoretically. Approximately 60% of the solar energy on the solar field is collected as useful heat in the salt. Heat losses of the tanks and pumping requirements of the salt, power block are relatively small, whereas auxiliary heating requires additional fossil fuel supplying additional 2.5% of thermal energy to the solar heated salted content to avoid freezing. An overall net efficiency of about 18% is expected to be achievable by such a concept.




Fig. 9: Exemplary Sankey Diagram for a parabolic trough power plant system using molten salt heat transfer and storage fluid

In Fig. 10 the potential for cost reduction is shown: the change to new and larger collector design (named UltimateTrough) together with a scale up from 50 to 100 MW power block size brings a reduction of almost 20 % in the levelized cost of electricity. If the thermal oil is replaced by the standard solar salt in this configuration an additional step of 20% is expected. Further scaling to 200MW block sizes anticipates a cost reduction of another 10% whereas the change to an advanced salt mixture has a potential to reduce the costs by another 3%. Thus the overall expectation is to achieve cost below 10€cents/kWh for flexible solar power by this concept [1].




Fig. 10: Cost reduction potential for future power tower systems using molten salt, ET refers to the EuroTrough technology with 5.6 m of aperture width and 105 m collector length, whereas UT refers to the UltimateTrough technology with 7.5 m of aperture and 200 m of collector length. SSe stands for the standard solar salt whereas HypoHitec foresees an advanced salt mixture with a lower freezing point at 150°C [1]

Today a first prototype system of 20 MW<sub>th</sub> power is installed in Sicily, Italy, providing the solar heat to the steam turbine system of a combined cycle power plants. Unfortunately, very little information on the performance of this system is available. In addition a couple of small demonstration loops exist or are under construction in different countries [6,13]. The experience with these facilities will help to find the best technical solutions to exploit this concept.

#### 4. Conclusions

The use of molten salt as heat transfer fluids offers a couple of potential benefits over the existing standard design of solar thermal power plant that is based on parabolic trough technology with thermal oil heat transfer fluid and an indirect molten salt storage concept. As the typical salt becomes solid at temperatures below 240°C, a significantly modified operation and maintenance concept is needed in that case. Commercial solar towers with molten salt as heat transfer and storage fluid are already being built and are more mature than parabolic trough systems based on molten salt. The parabolic through technology still must convince stakeholders that it permits practical and reliable safety measures against freezing of the salt. This can be achieved by draining of the solar field or by heating systems. A detailed analysis showed that the concept appears feasible and has a cost reduction potential similar to the one of solar towers to reach levelized electricity cost below 10 ¢cents/kWh. Both options also show room for further improvements if advanced salt mixtures are applied. They are therefore explored by research and industry.

#### Literature

1. Rügamer, T., H. Kamp, et al. (2013). Molten Salt for Parabolic Trough Applications: System Simulation and Scale Effects. 19th SolarPACES Conference, Las Vegas.
2. Drouot, L.P. and Hillairet, M.J., The Themis program and the 2500-KW Themis solar power station at Targasonne. *J. Sol. Energy Eng.* 106 (1), (1984) 83-89.
3. Martin, M.,(1985), Molten Salt Electric Experiment (MSEE), Sandia National Laboratories, SAND85-8175, Albuquerque, New Mexico
4. Bradshaw, R.W.; Dawson, D.B.; De La Rosa, W.; Gilbert, R.; Goods, S.H.; Hale, M.J.; Jacobs, P.; Jones, S.A.; Kolb, G.J.; Pacheco, J.E.; Prairie, M.R.; Reilly, H.E.; Showalter, S.K. and Vant-Hull, L.L.,(2002), Final Test and Evaluation Results from the Solar Two Project, OSTI ID: 793226,
5. Siegel, N. P., R. W. Bradshaw, et al. (2011). Thermophysical Property Measurement of Nitrate Salt Heat Transfer Fluids. ASME 2011 5th International Conference on Energy Sustainability ES2011, Washington, DC, USA.
6. Falchetta, M., D. Mazzei, et al. (2009). Design of Archimede 5MW molten salt parabolic trough solar plant presented at 15th Int. SolarPACES Symposium: September 15-18, Berlin, Germany.
7. Nissen, D.A. and Meeker, D.E., Nitrate/nitrite chemistry in sodium nitrate-potassium nitrate melts. *Inorganic Chemistry*, 1983. 22(5): p. 716-721.
8. Bradshaw, R.W. and Tyner, C.E.,(1988), Chemical engineering Factors Affecting Solar Central Receiver Applications of Ternary Molten Salts, Sandia National Laboratories, SAND88-8686, Albuquerque, New Mexico

9. Bauer, T.; Pflieger, N.; Laing, D.; Steinmann, W.-D.; Eck, M. and Kaesche, S. (2012), High temperature molten salts for solar power application, in Molten Salts: Fundamentals and Application, eds F. Lantelme and H. Groult), Elsevier (in press).
10. Kearney, D.; Kelly, B.; Herrmann, U.; Cable, R.; Pacheco, J.; Mahoney, R.; Price, H.; Blake, D.; Nava, P. and Potrovitza, N., Engineering aspects of a molten salt heat transfer fluid in a trough solar field. *Energy*, 2004. 29(5–6): p. 861-870.
11. Bradshaw, R.W. and Goods, S.H.,(2000), Corrosion Resistance of Nickel-Base Alloys in Molten alkali Nitrates, Sandia National Laboratories, SAND2000-8240, Albuquerque, New Mexico, USA
12. Müller-Elvers and Wittmann (2012) Design and Construction of Molten Salt Parabolic Trough HPS Project in Évora, Portugal in Proceedings of the 18th Int. SolarPACES Symposium, September 11-14, Marrakech, Morocco.
13. Burgaleta, J.A., S: (2011) A real CSP Experience - GEMASOLAR, the First Tower Thermosolar Commercial Plant with Molten Salt Storage presented at CSP Today Conference: Seville.
14. [http://www.nrel.gov/csp/solarpaces/power\\_tower.cfm](http://www.nrel.gov/csp/solarpaces/power_tower.cfm) (visited 21.5.2015)
15. IEA Technology Roadmap – Concentrating Solar Power, 2010 edition; [https://www.iea.org/media/freepublications/technologyroadmaps/csp\\_roadmap2010.pdf](https://www.iea.org/media/freepublications/technologyroadmaps/csp_roadmap2010.pdf) (visited 21.5.2014)
16. Reilly, H. E. and Kolb, G.J.,(2001), An Evaluation of Molten-Salt Power Towers Including Results of the Solar Two Project, Sandia National Laboratories, SAND2001-3674, Albuquerque, New Mexico, USA
17. Zavoico, A. B.,(2001), Solar Power Tower Design Basis Document, Sandia National Laboratories, SAND2001-2100, Albuquerque, New Mexico, USA
18. M.R. Rodriguez-Sanchez (2014); Saving assessment using the PERS in power towers. *Energy conversion and Management* Volume 87 November 2014 pp 810-819

Prof. Dr.-Ing. Robert Pitz-Paal, Dipl.-Ing. Stefano Giuliano, Dr.-Ing. Michael Wittmann  
 DLR Deutsches Zentrum für Luft- und Raumfahrt  
 Institute of Solar Research  
 Linder Höhe, D-51147 Köln  
 (postal address: D-51170 Köln)



## **Arbeitskreis Energie in der Deutschen Physikalischen Gesellschaft**

Direkter Link zum AKE - Archiv:

<http://www.uni-saarland.de/fak7/fze/index.htm>

Direkter Link zum AKE - Archiv, Tagung 2015 -Berlin:

[http://www.uni-saarland.de/fak7/fze/AKE\\_Archiv/DPG2015-AKE\\_Berlin/Links\\_DPG2015.htm](http://www.uni-saarland.de/fak7/fze/AKE_Archiv/DPG2015-AKE_Berlin/Links_DPG2015.htm)

Zur Sammlung der Tagungsbände des AKE auf dem DPG - Server:

<https://www.dpg-physik.de/veroeffentlichung/ake-tagungsband.html>

## **Vorträge auf der Berliner DPG-Tagung (2015)**

Herausgeber:  
Arbeitskreis Energie (AKE) in der DPG  
Prof. Dr. Hardo Bruhns  
Meliesallee 5  
40597 Düsseldorf  
E-Mail: [ake@bruhns.info](mailto:ake@bruhns.info)

Die Grafik des Einbandes wurde  
mit freundlicher Genehmigung der  
Autoren unter Verwendung von  
Abbildungen aus den Beiträgen von  
H. Milsch, M. Waidhas und F.  
Wagner gestaltet.

# Energie

Erzeugung - Netze - Nutzung

Vorträge auf der DPG-Frühjahrstagung in Berlin 2015

Arbeitskreis Energie in der Deutschen Physikalischen Gesellschaft

Herausgegeben von Hardo Bruhns

Bad Honnef, September 2015

Frühjahrstagung des Arbeitskreises Energie  
in der Deutschen Physikalischen Gesellschaft  
Berlin, 16. bis 18. März 2015

Haupt- und Fachvorträge

Inhaltsverzeichnis / Table of Contents

Introduction	7
Fachsitzungen / Sessions	8
Abstracts	9
Organic Photovoltaics: Status and Perspectives - presented by J. Widmer	28
Concepts for Cost Reduction in CSP Power Plants - presented by R. Pitz-Paal	42
Optionen und Trends der Biomassenutzung – Perspektiven für die Bioenergie 2050 - vorgetragen von J. Ponitka	53
Deep Geothermal Fluid Resources: Energetic Use and Beyond - presented by H. Milsch	63
Geological Carbon Storage: Processes, Risks and Opportunities - presented by H. Ott	77
„Fracking“ – Routine oder Risikotechnologie? - vorgetragen von M. Kosinowski	94
Power to Gas – an Economic Approach for Energy Storage? - presented by M. Waidhas	107
Nuclear Fission Energy: New Build, Operation, Fuel Cycle and Decommissioning in the International Perspective - presented by S. Nießen	113

Wendelstein 7-X – Ein Konzept für ein stationäres Fusionsplasma	122
- vorgetragen von R. C. Wolf	
Neue Materialien und Komponenten für energieeffiziente Gebäudehüllen	131
- vorgetragen von U. Heinemann	
Eigenschaften einer Stromversorgung mit intermittierenden Quellen	138
- vorgetragen von F. Wagner	
Transient Stability of Conventional Power Generating Stations during Times of High Wind Penetration	156
- presented by M. Zarifakis	
Ganzheitliche Bewertung von Energiesystemen	168
- vorgetragen von R. Friedrich	
Impressum	183

Der vorliegende Band versammelt schriftliche Ausarbeitungen von Vorträgen auf der Tagung des Arbeitskreises Energie in der Deutschen Physikalischen Gesellschaft des Jahres 2015 in den Räumen der Technischen Universität Berlin. Leider ist es nicht gelungen, von allen Vortragenden Manuskripte zu erhalten. Die Präsentationsfolien der meisten Hauptvorträge können auf der Webseite des Arbeitskreises über:

<http://www.dpg-physik.de/dpg/organisation/fachlich/ake.html>

(von dort gelangt man zum Archiv des AKE) eingesehen werden. Allen, die zu diesem Sammelband beigetragen haben, sei an dieser Stelle sehr herzlich gedankt.